

SWANSON, Sharon
DAVIS, Steven

FINAL INSPECTION SHEET (SAND FILTER)

TOWNSHIP Hanover

WATER SUPPLY (WELL) (PUBLIC)

PERMIT NUMBER PSD 63-104-87

LOCATION 292 Nashville Rd.

EXPANSION ATTIC (YES) (NO)

HOUSE PLUMBING

- All sewage connected
- Water softener excluded
- Clean out in house
- 1 1/2 bathroom(s)
- footer drain sump excluded
- 7 1/4" foot grade to tank
- kitchen
- laundry
- None garbage disposal
- access to house

SEPTIC TANK

#1	Size	Existing	Brand	#2	Portland	Size	Brand
<input checked="" type="checkbox"/>	<u>1000</u>	<u>Existing</u>		<input checked="" type="checkbox"/>	<u>NR</u>	<u>500</u>	
<input checked="" type="checkbox"/>		Extends to surface	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Tanks level		<u>NR</u> clean outs
<input checked="" type="checkbox"/>		All joints sealed	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	SCH. #40 out	<u>#1</u>	liquid depth
<input checked="" type="checkbox"/>		SCH. #40 into tank	<input checked="" type="checkbox"/>		Min. 18" baffle	<u>#2</u>	liquid depth
<input checked="" type="checkbox"/>		Min. 16" baffle			10' min. from house		50' min. to well

GRAVEL FILTER BOX (YES) (NO)

LOCATION 10 toward house from D Box -

WET WELLS

- Approved tank
- Approved type pump installed
- Make & Model of Pump _____
- Wet well sealed from surface water
- Wet well accessible to ground level
- _____ float type switch
- _____ brass or nylon impeller

DISTRIBUTION BOX

- Top 0" to 12" below finished grade
- Inlet 2" above outlets
- Water available for testing
- Dist. box placed on sand, stone or cement blocks
- 02-9144x 5010
- Outlets equal distribution
- Joints cemented and tarred
- Down-turned ~~vented~~ elbow on inlet - T
- Watertight box and cover

SAND FILTERS

- Approved sand (origin) MAS110
- Sand been pre-soaked for settling
- Depth sand (24" minimum)
- 8" Depth of stone over sand
- Holes on bottom
- 8" Depth of stone under sand
- Ends of lines capped
- 32' Length of lines

LEACH BED AFTER FILTERS

Size & Type of Leach area 2' x 100' - 60 to 60ft 40' to right

(Sketch on Back)

Comments:

[Signature]
Installer's signature

[Signature]
Inspector's signature

8/14/87
Date

